

# LUX THERMOSTATS

## INTEROFFICE MEMO

Date: May 4, 2012

To: Abigail Dakin, US EPA

From: Steve Millheiser, VP Marketing

Subject: **Lux Products Corp. comments on Draft 3.0 Version 1.0 Climate Control Energy Star Specs**

We appreciate the changes EPA has made since the previous draft was proposed. Below are a few questions we have regarding the latest proposal.

3.D.1b We question the necessity of requiring a month/day/year format for programming. This would impose software costs to the manufacturer that do not directly relate to energy savings.

3.D.1c Some default setback/setup temperatures seem a bit strident considering the recovery time it might require in some extreme climatic zones.

3.D.3 Will target and maximum times for all tasks tested with direct thermostat interface be the same as with remote interface?